

## KENAI PENINSULA BOROUGH

144 North Binkley Street ◆ Soldotna, Alaska 99669-7520 Toll-free within the Borough: 1-800-478-4441 PHONE: (907) 262-4441 ◆ FAX: (907) 262-1892 www.borough.kenai.ak.us

MIKE NAVARRE BOROUGH MAYOR

## **MEMORANDUM**

TO:

Assembly President Gary Knopp

Kenai Peninsula Borough Assembly Members

THRU:

Mayor Mike Navarre

FROM:

Chief James Baisden

**DATE:** 

January 3, 2012

**SUBJECT:** 

Ordinance 2011-19-58: Appropriating \$30,000 from the Nikiski Fire Service Area

Capital Project Fund for a Corrosive Water Mitigation System at Nikiski Fire

Station #2

This memo corrects the memo dated November 23, 2011, and questions raised by the assembly at introduction.

The water for the new Nikiski Fire Station #2 is provided by Nikishka Bay Utilities. The water has a low pH (acidic) level and is considered corrosive. Due to its low pH level, it will have a negative long term impact on the piping, equipment and appliances at Fire Station #2.

Installation of a chemical injection system will mitigate the corrosive nature of the water. The proposed system will inject sodium hydroxide NA OH (Caustic Soda) to neutralize the acidic pH of the water. This system has been used in similar conditions with success. The cost of the chemical injection system is estimated to be between \$25,000 and \$30,000.

At its November 9, 2011, board meeting, the Nikiski Fire Service Area Board approved the use of \$30,000 from the Nikiski Fire Service area Capital Project Fund, fund balance for the purchase and installation of a chemical injection system.

Please amend the second and third whereas clauses in Ordinance 2011-19-58, as follows:

WHEREAS, water supplied by Nikishka Bay Utilities has a [HIGH] <u>low</u> [PH] <u>pH</u> level and is considered corrosive; and

WHEREAS, Although drinkable, because of its [HIGH] <u>low</u> [PH] <u>pH</u> level, it will have a negative long term impact on the piping, equipment and appliances at Fire Station #2; and

Your consideration is appreciated.