

Introduced by: Mayor
Date: 12/06/11
Hearing: 01/03/12
Action: Enacted as Amended
Vote: 9 Yes, 0 No, 0 Absent

**KENAI PENINSULA BOROUGH
ORDINANCE 2011-19-58**

**AN ORDINANCE APPROPRIATING \$30,000 FROM THE NIKISKI FIRE SERVICE
AREA CAPITAL PROJECT FUND FOR A CORROSIVE WATER MITIGATION
SYSTEM AT NIKISKI FIRE STATION #2**

WHEREAS, water for the new Nikiski Fire Station #2, is provided by Nikishka Bay Utilities; and

WHEREAS, water supplied by Nikishka Bay Utilities has a low pH level and is considered corrosive; and

WHEREAS, although drinkable, because of its low pH level, it will have a negative long term impact on the piping, equipment and appliances at Fire Station #2; and

WHEREAS, installation of a chemical injection system will mitigate the corrosive nature of the water that is being supplied by Nikishka Bay Utilities; and

WHEREAS, the cost of a chemical injection system is estimated to be between \$25,000 and \$30,000; and


WHEREAS, the Nikiski Fire Service Area Board at its November 9, 2011, meeting approved the use of \$30,000 from the Nikiski Fire Service Area Capital Project Fund, fund balance for the purchase and installation of a chemical injection system;

NOW, THEREFORE, BE IT ORDAINED BY THE ASSEMBLY OF THE KENAI PENINSULA BOROUGH:

SECTION 1. That \$30,000 is appropriated from the Nikiski Fire Service Area Capital Project Fund, fund balance to account number 441.51111.12COR.49999 for the purchase and installation of a chemical injection system at Nikiski Fire Station #2.


SECTION 2. That this ordinance takes effect immediately upon its enactment.

ENACTED BY THE ASSEMBLY OF THE KENAI PENINSULA BOROUGH THIS 3RD DAY OF JANUARY, 2012.




Gary Knopp, Assembly President

ATTEST:



Johni Blankenship, Borough Clerk



Yes: Haggerty, Johnson, McClure, Murphy, Pierce, Smalley, Smith, Tauriainen, Knopp
No: None
Absent: None